



November 15, 2017

██████████
 C/O Oaks of Rockford
 ██████████
 Rockford, MI 49341
 ██████████

RE: Residential Well Water Sampling Results

Dear Brian:

Attached is the laboratory report from a sample we recently collected from your potable well. The sample was analyzed by ALS in Kelso, Washington for a limited number of perflourinated compounds including perfluorooctylsulfonic acid (PFOS) and perfluorooctanoic acid (PFOA).

The sample was un-treated groundwater collected from an aerator-free tap in the well-house. The laboratory report is summarized below. For reference, the table includes the Lifetime Health Advisories (LHA) developed in 2016 by the Environmental Protection Agency (EPA). LHAs are non-enforceable and non-regulatory and are intended to provide state agencies and other public health officials with general guidance on contaminants that can cause human health effects. Non-PFOs/PFOA compounds do not currently have LHAs.

Summary of Laboratory Results				
Sample	PFOS/PFOA Detected	Total PFOS/PFOA Detected (ppt)	Above or Below EPA PFOS/PFOA Lifetime Advisory (70 ppt, or ng/l)	Non-PFOS/PFOA detected
Potable Well	No	None	Below	None
Field Blank	No	None	Below	None

Thank you for using the services of F&V. If you need additional information, please contact me.

Sincerely,
 FLEIS & VANDENBRINK

Brian L. Rice, P.E.
 Manager, Environmental Services Group

att: Laboratory Report and Chain of Custody
 cc: Mark Worrall, MDEQ
 Karen Vorce, MDEQ

2960 Lucerne Drive SE, Suite 100
Grand Rapids, MI 49546
 P: 616.977.1000
 F: 616.977.1005
 www.fveng.com